

2014 Lead and Copper Monitoring at Customers' Tap								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Action Level AL	90 <sup>th</sup> Percentile Value*	Number of Samples Over AL	Violation yes/no	Major Sources in Drinking Water
Lead	2014	ppm	0	.015	0 ppm	0	No	Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2014	ppm	1.3	1.3	0.12 ppm	0	No	Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.
*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.								

Revisions to the 2015 Consumer Confidence Report are shown in red. Units shown have been changed from parts per billion to parts per million. Should you have any questions? Please contact the Department of Public Works at 586-749-0230 Monday-Thursday 8:30 to 5:00.